

Date : 24/07/2025

(Name of Officers
with designation) from श्री अनुराग अग्रवाल जी का कार्यालय (Name of
Department/Office) inspected the SHIV JYOTI CONVENT SCHOOL, MAHAVEER
NAGAR EXTENSION, SECTOR-1, KOTA (Name & Address of
the School) on 17/07/2025 and found that the SHIV JYOTI CONVENT SCHOOL
MAHAVEER NAGAR EXTENSION, SECTOR-1 (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year

Designation : नगर निगम कोटा दक्षिण

SHIV JYOTI CONVENT SCHOOL
MAHAVEER NAGAR EXTENSION
SECTOR-1, KOTA - RGT

(Name & Address of the Institution)



OFFICE OF THE SENIOR CHEMIST
REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN
 PHED Campus, AKELGARH KOTA-324010



Test Report
(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)

Desp. No. : **SSO**

Dated : **12/8/25**

Issued to:

Principal

Shiv Jyoti Convent School M.N. Ext. Sec. 1
Kota

District: **Kota**

Block/City: **Kota**

Sample Not Collected by Lab

Ref ID	10	Sample Code No.		PC-76 PB-71
Reference : Letter No.		NM	Source :	R.O.
Reference Date:		06.08.25	Source Location :	Shiv Jyoti Convent School M.N. Ext.
Date of Receipt :		06.08.25	Habitation/Ward No. :	-
Sample ID	18			
Name of Sample Collector:		Krishan Murari	Village/Colony/Nagar :	Kota
Designation of Sample Collector:		0	Gram Panchayat/City Area :	-
Latitude of Location			Date of Collection :	06.08.25
Longitude of Location			Start Date of Examination :	06.08.25
Elevation of Location			End Date of Examination :	12.08.25
Test Parameters		IS-10500:2012(RA 2018)		Sample Report No.
		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:
				Test Values
1	pH At Temp. 25 ⁰ C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022
2	Turbidity	1.0	5.0	-
3	Taste	Not Defined	Not Defined	-
4	Odour	Unobjectionable	Unobjectionable	-
5	Total Alkalinity (as CaCO ₃) mg/l	200	600	[IS 3025, P-23], 1986 (RA2023)
6	Total Hardness (as CaCO ₃) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2023)
7	Calcium (as Ca ⁺⁺) mg/l	75	200	[IS 3025, P-40], 1991 (RA 2024)
8	Magnesium (as Mg ⁺⁺) mg/l	30	100	[IS 3025, P-46], 1994 (RA 2023)
9	Chloride (as Cl ⁻) mg/l	250	1000	[IS 3025, P-32],1988 (RA 2019)
10	Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO3: 2022
11	Fluoride (as F ⁻) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2023)
12	Total Dissolved Solids (TDS) mg/l At 180 ⁰ C	500	2000	[IS 3025 P-16]:1983 (RA 2023) /APHA, Ed24, 2510-B] Cond.2022
11	Total Coliform (MPN/100ml)	Nil	Nil	-

(*ADL= Above detection limit; BDL= Below detection limit)

**REPORT IS NOT VALID FOR
 JUDICIAL AND COMMERCIAL
 PURPOSE**

Authorized Signatory

(Signature)
 Senior Chemist

PHED Reg.Lab. Kota

NOTE:

- 1 This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- 2 This test report reletes only to the samples/items submitted to the laboratory for test.
- 3 This report is not valid for legal cases/legal purposes.
- 4 Sample will be preserved only for 15 days from date of receipt.
- 5 Measurement of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----